

Annexure V

Title: Pressure differential, noise and Illumination test	Ref. SOP No.:
Format No.:	Revision No.:

Date: _____

Pressure Differential Test

Magnehelic gauge No-	
Air Pressure difference Across HEPA	
Acceptance criteria	8 to 15 mmwc

Remarks:

Observed By: _____ Checked By: _____

Noise Test

Sound Level Meter No.	
Noise level observed	
Acceptance criteria	NMT 80 dB

Remarks:

Observed By: _____ Checked By: _____

Illumination Test

Lux meter No.	
Illumination Intensity	
Acceptance criteria	NLT 150 Lux

Remarks:

Observed By: _____ Checked By: _____